



Creative Minds PCS - Lead in Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Filter Test ID	FT Final Results - Draw A (ppb)	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right					
Creative Minds PCS	WS-055-001	Cooler	Ground	In hallway adjacent to room 008	High	Left	WF-112017-055001-01	3/23/18	FT-FY18-112017-055001	<1	<1
Creative Minds PCS	WS-055-002	Bottle Filler	Ground	In hallway adjacent to room 008	High	Right	WF-112017-055002-01	3/23/18	FT-FY18-112017-055002	<1	<1
Creative Minds PCS	WS-055-003	Cooler	Ground	In hallway adjacent to room 008	Low	Right	WF-112017-055003-01	3/23/18	FT-FY18-112017-055003	<1	<1
Creative Minds PCS	WS-055-004	Food Prep Sink	Ground	In kitchen 017	-	-	WF-112017-055004-01	3/23/18	FT-FY18-112017-055004	<1	<1
Creative Minds PCS	WS-055-005	Break Room	Ground	In faculty lounge 024	-	-	WF-112017-055005-01	3/23/18	FT-FY18-112017-055005	<1	<1
Creative Minds PCS	WS-055-006	Health Suite	Ground	In nurse suite 026	-	-	WF-112017-055006-01	3/23/18	FT-FY18-112017-055006	1.0	<1
Creative Minds PCS	WS-055-007	Cooler	1	In cafeteria 100	High	Left	WF-112017-055007-01	3/23/18	FT-FY18-112017-055007	<1	<1
Creative Minds PCS	WS-055-008	Bottle Filler	1	In cafeteria 100	High	Right	WF-112017-055008-01	3/23/18	FT-FY18-112017-055008	<1	<1
Creative Minds PCS	WS-055-009	Cooler	1	In cafeteria 100	Low	Right	WF-112017-055009-01	3/23/18	FT-FY18-112017-055009	<1	<1
Creative Minds PCS	WS-055-011	Cooler	2	In hallway adjacent to room 213	High	Left	WF-112017-055011-01	3/23/18	FT-FY18-112017-055011	<1	<1
Creative Minds PCS	WS-055-012	Bottle Filler	2	In hallway adjacent to room 213	High	Right	WF-112017-055012-01	3/23/18	FT-FY18-112017-055012	<1	<1
Creative Minds PCS	WS-055-013	Cooler	2	In hallway adjacent to room 213	Low	Right	WF-112017-055013-01	3/23/18	FT-FY18-112017-055013	<1	<1
Creative Minds PCS	WS-055-014	Cooler	3	In hallway adjacent to boys restroom	High	Left	WF-112017-055014-01	3/23/18	FT-FY18-112017-055014	<1	<1
Creative Minds PCS	WS-055-015	Bottle Filler	3	In hallway adjacent to boys restroom	High	Right	WF-112017-055015-01	3/23/18	FT-FY18-112017-055015	<1	<1
Creative Minds PCS	WS-055-016	Cooler	3	In hallway adjacent to boys restroom	Low	Right	WF-112017-055016-01	3/23/18	FT-FY18-112017-055016	<1	<1