



Creative Minds PCS - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Creative Minds PCS	WS-055-001	Cooler	Ground	In hallway adjacent to room 008	High	Left	WF-082019-055001-02	10/22/2019	FT-FY20-082019-055001-A	<1	FT-FY20-082019-055001-B	<1
Creative Minds PCS	WS-055-003	Cooler	Ground	In hallway adjacent to room 008	Low	Right	WF-082019-055003-02	10/22/2019	FT-FY20-082019-055003-A	<1	FT-FY20-082019-055003-B	<1
Creative Minds PCS	WS-055-004	Food Prep Sink	Ground	In kitchen 017			WF-082019-055004-02	10/22/2019	FT-FY20-082019-055004-A	<1	FT-FY20-082019-055004-B	<1
Creative Minds PCS	WS-055-005	Break Room	Ground	In faculty lounge 024			WF-082019-055005-02	10/22/2019	FT-FY20-082019-055005-A	<1	FT-FY20-082019-055005-B	<1
Creative Minds PCS	WS-055-006	Health Suite	Ground	In nurse suite 026			WF-082019-055006-02	10/22/2019	FT-FY20-082019-055006-A	1	FT-FY20-082019-055006-B	<1
Creative Minds PCS	WS-055-007	Cooler	1	In cafeteria 100	High	Left	WF-082019-055007-02	10/22/2019	FT-FY20-082019-055007-A	<1	FT-FY20-082019-055007-B	<1
Creative Minds PCS	WS-055-009	Cooler	1	In cafeteria 100	Low	Right	WF-082019-055009-02	10/22/2019	FT-FY20-082019-055009-A	<1	FT-FY20-082019-055009-B	<1
Creative Minds PCS	WS-055-011	Cooler	2	In hallway adjacent to room 213	High	Left	WF-082019-055011-02	10/22/2019	FT-FY20-082019-055011-A	<1	FT-FY20-082019-055011-B	<1
Creative Minds PCS	WS-055-012	Bottle Filler	2	In hallway adjacent to room 213	High	Right	WF-082019-055012-02	10/22/2019	FT-FY20-082019-055012-A	<1	FT-FY20-082019-055012-B	<1
Creative Minds PCS	WS-055-013	Cooler	2	In hallway adjacent to room 213	Low	Right	WF-082019-055013-02	10/22/2019	FT-FY20-082019-055013-A	<1	FT-FY20-082019-055013-B	<1
Creative Minds PCS	WS-055-014	Cooler	3	In hallway adjacent to boys restroom	High	Left	WF-082019-055014-02	10/22/2019	FT-FY20-082019-055014-A	<1	FT-FY20-082019-055014-B	<1
Creative Minds PCS	WS-055-015	Bottle Filler	3	In hallway adjacent to boys restroom	High	Right	WF-082019-055015-02	10/22/2019	FT-FY20-082019-055015-A	1	FT-FY20-082019-055015-B	<1
Creative Minds PCS	WS-055-016	Cooler	3	In hallway adjacent to boys restroom	Low	Right	WF-082019-055016-02	10/22/2019	FT-FY20-082019-055016-A	<1	FT-FY20-082019-055016-B	<1

Greater than 5 ppb - Devices Requiring Remediation												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Creative Minds PCS	WS-055-002	Bottle Filler	Ground	In hallway adjacent to room 008	High	Right	WF-082019-055002-02	10/22/2019	FT-FY20-082019-055002-A	<1	FT-FY20-082019-055002-B	8.6

Less than 5 ppb - Devices Requiring No Remediation (After Plumbing Check)												
Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Creative Minds PCS	WS-055-002	Bottle Filler	Ground	In hallway adjacent to room 008	High	Right	WF-102019-055002-02	11/4/2019	FT-FY20-102019-055002-A	<1	FT-FY20-102019-055002-B	<1