



Creative Minds PCS - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Creative Minds PCS	WS-055-001	Cooler	Ground	In hallway adjacent to room 008	High	Left	WF-022025-055001-09	5/1/2025	FT-FY25-022025-055001-A	<1	FT-FY25-022025-055001-B	<1
Creative Minds PCS	WS-055-002	Bottle Filler	Ground	In hallway adjacent to room 008	High	Right	WF-022025-055002-08	5/1/2025	FT-FY25-022025-055002-A	<1	FT-FY25-022025-055002-B	<1
Creative Minds PCS	WS-055-003	Cooler	Ground	In hallway adjacent to room 008	Low	Right	WF-022025-055003-08	5/1/2025	FT-FY25-022025-055003-A	<1	FT-FY25-022025-055003-B	<1
Creative Minds PCS	WS-055-004	Food Prep Sink	Ground	In kitchen 017			WF-022025-055004-07	5/1/2025	FT-FY25-022025-055004-A	<1	FT-FY25-022025-055004-B	<1
Creative Minds PCS	WS-055-005	Break Room	Ground	In faculty lounge 024			WF-022025-055005-07	5/1/2025	FT-FY25-022025-055005-A	<1	FT-FY25-022025-055005-B	<1
Creative Minds PCS	WS-055-006	Health Suite	Ground	In nurse suite 026			WF-022025-055006-07	5/1/2025	FT-FY25-022025-055006-A	<1	FT-FY25-022025-055006-B	<1
Creative Minds PCS	WS-055-007	Cooler	1	In cafeteria 100	High	Left	WF-022025-055007-07	5/1/2025	FT-FY25-022025-055007-A	<1	FT-FY25-022025-055007-B	<1
Creative Minds PCS	WS-055-008	Bottle Filler	1	In cafeteria 100	High	Right	WF-022025-055008-07	5/1/2025	FT-FY25-022025-055008-A	<1	FT-FY25-022025-055008-B	<1
Creative Minds PCS	WS-055-009	Cooler	1	In cafeteria 100	Low	Right	WF-022025-055009-07	5/1/2025	FT-FY25-022025-055009-A	<1	FT-FY25-022025-055009-B	<1
Creative Minds PCS	WS-055-011	Cooler	2	In hallway adjacent to room 213	High	Left	WF-022025-055011-07	5/1/2025	FT-FY25-022025-055011-A	<1	FT-FY25-022025-055011-B	<1
Creative Minds PCS	WS-055-012	Bottle Filler	2	In hallway adjacent to room 213	Low	Right	WF-022025-055012-07	N/A	FT-FY25-022025-055012-A	Non-operational	FT-FY25-022025-055012-B	Non-operational
Creative Minds PCS	WS-055-013	Cooler	2	In hallway adjacent to room 213	Low	Right	WF-022025-055013-07	N/A	FT-FY25-022025-055013-A	Non-operational	FT-FY25-022025-055013-B	Non-operational
Creative Minds PCS	WS-055-014	Cooler	3	In hallway adjacent to boys restroom	High	Right	WF-022025-055014-07	5/1/2025	FT-FY25-022025-055014-A	<1	FT-FY25-022025-055014-B	<1
Creative Minds PCS	WS-055-015	Bottle Filler	3	In hallway adjacent to boys restroom	Low	Right	WF-022025-055015-07	5/1/2025	FT-FY25-022025-055015-A	<1	FT-FY25-022025-055015-B	<1
Creative Minds PCS	WS-055-016	Cooler	3	In hallway adjacent to boys restroom	High	Left	WF-022025-055016-07	5/1/2025	FT-FY25-022025-055016-A	<1	FT-FY25-022025-055016-B	<1
Creative Minds PCS	WS-055-021	Bottle Filler	Ground	In hallway adjacent to room 034	High	Left	WF-022025-055021-04	5/1/2025	FT-FY25-022025-055021-A	<1	FT-FY25-022025-055021-B	<1
Creative Minds PCS	WS-055-023	Cooler	Ground	In hallway adjacent to room 034	High	Left	WF-022025-055023-04	5/1/2025	FT-FY25-022025-055023-A	<1	FT-FY25-022025-055023-B	<1
Creative Minds PCS	WS-055-024	Cooler	Ground	In hallway adjacent to room 034	Low	Right	WF-022025-055024-04	5/1/2025	FT-FY25-022025-055024-A	<1	FT-FY25-022025-055024-B	<1
Creative Minds PCS	WS-055-025	Bottle Filler	Ground	In hallway adjacent to room 008			WF-022025-055025-03	5/1/2025	FT-FY25-022025-055025-A	<1	FT-FY25-022025-055025-B	<1
Creative Minds PCS	WS-055-026	Bottle Filler	Ground	In hallway adjacent to room 034			WF-022025-055026-03	5/1/2025	FT-FY25-022025-055026-A	<1	FT-FY25-022025-055026-B	<1
Creative Minds PCS	WS-055-027	Bottle Filler	1	In cafeteria 100			WF-022025-055027-03	5/1/2025	FT-FY25-022025-055027-A	<1	FT-FY25-022025-055027-B	<1
Creative Minds PCS	WS-055-028	Bottle Filler	2	In hallway adjacent to room 213			WF-022025-055028-03	5/1/2025	FT-FY25-022025-055028-A	<1	FT-FY25-022025-055028-B	<1
Creative Minds PCS	WS-055-029	Bottle Filler	3	In hallway adjacent to boys restroom			WF-022025-055029-03	5/1/2025	FT-FY25-022025-055029-A	<1	FT-FY25-022025-055029-B	<1